

Corrigendum #2 dated: 03.04.2024

TENDER FOR HIRING OF AGENCY FOR PROVIDING OPERATION AND COMPREHENSIVE ANNUAL MAINTENANCE SERVICE OF BOOSTER COMPRESSORS INSTALLED AT AMBALA-KURUKSHETRA & KOLHAPUR GA

TENDER NO. HOGPL/2023-24/C&P/016 DATE: 19.03.2024

Sl. No.	Tender Reference Clause	Description of Clause		Amendment/Addition/Modification/Deletion
1	Point no. f of Clause no. 3.2 of Technical Volume	The Contractor shall use only OEM's certified spares during maintenance. In case, the schedule maintenance of the OEM manual recommends checking and replacing parts like valves, regulators, hoses, piston rings etc. after certain time interval, same shall be replaced or used further only on approval from the HOGPL representative. However, any untoward consequences for non-replacement of such parts shall be the responsibility of the Contractor.	Modification	The Contractor shall use only OEM's certified spares during maintenance. The schedule maintenance of the OEM manual recommends checking and replacing parts like valves, regulators, hoses, piston rings etc. after certain time interval, same shall be replaced or used further only on approval from the HOGPL representative. Any untoward consequences for non-replacement of such parts shall be the responsibility of the Contractor. In case, OEM certified spares are not available HOGPL may approve the installation of OEM equivalent spares; however, contractor should submit all the technical details of equivalent spares to the concerned EIC prior to installation for approval.

Note: This Corrigendum shall form an integral part of the bidding document and shall be signed/stamped and submitted along with the bid. All other terms and conditions shall remain un-changed.

Signature & Seal of Bidder