

Corrigendum #3 dated: 06-03-2025

**TENDER FOR SUPPLY OF NATURAL GAS SERVICE REGULATOR FOR CITY GAS DISTRIBUTION OF AMBALA-KURUKSHETRA & KOLHAPUR GA**

**TENDER NO. HOGPL/2024-25/C&P/021 DATE: 17.02.2025**

Sl. No.	Tender Refernace Clause	Description of Cluase		Amendment/Addition/Modification/Deletion
<b>TECHNICAL VOLUME</b>				
1	<b>Clause No. 4 Technical Requirements</b>	Regulator shall be double stage pilot pressure loading	Amendment	For 100 SCMH: Regulator shall be Double stage pilot pressure loading. For 200 SCMH: Regulator shall be Single stage pilot pressure loading.
2	<b>Clause No. 14 Data sheet for Service Regulator</b>	Type of Regulator: Direct actuating with spring control & diaphragm with in-built pressure balance	Amendment	For 100 SCMH: Double stage Direct actuating with spring control & diaphragm with in-built pressure balance. For 200 SCMH: Single Stage Direct actuating with spring control & diaphragm with in-built pressure balance.
<b>Note: This Corrigendum shall form an integral part of the bidding document and shall be signed/stamped and submitted along with the bid. All other terms and conditions ahall remain un-changed.</b>				

Signature & Seal of Bidder